

ADDENDUM



Project: Old Fraser River Bridge Landing Plaza Upgrades
Owner: City of Quesnel
Date: February 21, 2023
File: 1190.0193.01-T

This Addendum is issued prior to Tender Closing Date, in accordance with the Tender Documents and shall be considered an integral part of the Contract Documents, read together with the Drawings, Specifications and Addenda previously issued and with all subsequent Addenda.

1.0 QUESTIONS AND ANSWERS:

1. Will you be reviewing and accepting equal alternates on the lighting fixtures?

Answer: Alternative products will no longer be reviewed. Alternative Tenders may be submitted in accordance with the Instructions to Tenderers – Part II Clause 6.2 and 6.3.

2.0 SUPPLEMENTARY SPECIFICATIONS:

Section 03 30 53 Cast-In-Place Concrete

Delete Clause 2.1.10 and replace with:

.10 Portland-limestone cement to CSA A3000.

3.0 CONTRACT DRAWINGS:

Add the following note to drawing L02:

D. Materials

6. All cast-in-place concrete to be in accordance with Section 03 30 20 Concrete Walks, Curbs and Gutters.

Please ensure receipt of this Addendum is acknowledged on the Form of Tender.

URBAN SYSTEMS LTD.

A handwritten signature in black ink, appearing to read 'Erik Green', written over a horizontal line.

[Erik Green, Contract Administrator]
Contract Administrator

U:\Projects_KAM\1190\0193\01\T-Tenders-Contracts\Addendum_01\Addendum_01.docx