



## **Q&A - Invitation to Tender - Asphalt road repairs and patching**

**Q - Is a minimum charge applicable for each patch location regardless of the size of the patch?**

**A -** Each patch will meet a minimum cost (it will not be added to other unit prices). The intent is for small patches where the patch could be 1 to 8 square meters for example, to cover mobilization/demobilization to patch location.

**Q - Is the minimum charge applicable for the first patch completed in the morning?**

**A -** No, it is not an added cost to other unit prices. It is intended as a minimum price to be charged for a paving patch.

**Appendix B specifies the thickness of asphalt as 65 to 70mm.**

**Q - Does the specified thickness include level course plus 50mm overlay?**

**A -** Specified thickness will be determined on a location to location basis and level course is required at very few locations. The need for level course will be minimal as most work will be full depth mill and replacement or full depth paving. If a project requires a level course additional pricing for that level course will be negotiated on a location basis.